

**CONTROLLING OFFICER'S REPLY TO
INITIAL WRITTEN QUESTION**

FHB(FE)093

Head: 49 Food and Environmental Hygiene Department Subhead 603 Plant, vehicles
(No. & title): and equipment

Question Serial No.

0964

Programme:

Controlling Officer: Director of Food and Environmental Hygiene

Director of Bureau: Secretary for Food and Health

Question:

Please advise on the details as well as the commencement and completion dates of the project on enhancement of the exhaust air extraction system of the cooked food centre at Tai Po Hui Market under the Capital Account for 2010-11. Has consultation with the traders been duly arranged?

Asked by: Hon. TONG Ka-wah, Ronny

Reply:

The project involves installation of supplementary exhaust air fans, frequency inverters, silencers and air ducts for each of the three water scrubbing systems serving the cooked food centre of Tai Po Hui Market. Other enhancements such as re-arrangement of the existing water scrubbing systems and/or installation of other flue gas treatment facilities of the cooked food centre are also being considered. Specification of works will be finalized by July 2010 for completion of project by February 2011. We will consult the Market Management Consultation Committee and the tenants concerned before starting the project.

Signature _____

Name in block letters _____

W H CHEUK

Post Title _____

Director of
Food and Environmental Hygiene

Date _____

15.3.2010